



### **Bid Review Questions**

1. Confirm Performance bond(s) are included in Bid.
2. Confirm all required insurances are included in Bid.
3. Please provide Manufacturer/Model number of Generator included in your bid. Include confirmation that bid includes radiator mounted load bank. Identify Lead time for bid unit.
4. Basis of Design generator was Caterpillar, if bid included other than Caterpillar, provide documentation ensuring that it will fit within the space allocated and fuel delivery and exhaust system will not need to be modified substantially.
5. Identify the amount of money that would be added to your bid if the bid unit were rejected and the Basis of Design generator were to be provided.
6. Explain what the individual dollar values for Items 1, 3, 4, 5, 6 & 7 from the RFP requested breakdown represent as far as what scope is included.
7. Are all costs associated with the replacement of the existing 250kW generator exhaust stack with a new exhaust stack for the new 1250kW generator including framing, supports, thimble, architectural wall repairs and containment?
8. Where are costs for Mechanical work carried?
9. Upon Contract Award, confirm you are ready to provide:
  - a. Proposed project schedule indicating expected project duration, including anticipated lead times for major equipment.
  - b. Schedule identifying how many shutdowns with a duration greater than 1-hour are anticipated.
  - c. Schedule identifying how many shutdowns with a duration less than 1-hour are anticipated?
  - d. Any proposed adjustments to the Proposed Sequence of Construction that would provide anticipated time and/or cost savings?